


2019.004.0009 52 X

# HOW WATER IN PHILADELPHIA IS TREATED AND DISTRIBUTED

1973



***Facts and Charts***

## SOURCES AND DISTRIBUTION

Where does Philadelphia get its water?

The city pumps one-half of its water from the Delaware River, just above the outlet of Pennypack Creek. The other half is pumped from the Schuylkill River at two different locations: the Belmont Pumping Station on the west side, just below Columbia Avenue Bridge, and the Queen Lane Pumping Station on the east side, just below City Line Bridge. The Belmont Station pumps from the pool formed by the Fairmount Dam, while the Queen Lane Station draws water from the head of the same pool.

All sources are located within the city and, with minor exceptions, all service is within the city limits.

After treatment and filtration, the major part of the effluent (or output) of the Belmont and Queen Lane Plants is delivered through the distribution system by gravity. This is possible because these plants have filtered water basins with water level elevations of 239 and 216 feet respectively.

The other effluents from Belmont and Queen Lane—and all the effluent from the Torresdale Plant—are pumped by stations located at, or near the plants, and some effluents are repumped at six booster stations. Pumping helps to maintain the gradients required for satisfactory pressures and good service at all points in the distribution system.

Normally about one-third of plant output is delivered by gravity and two-thirds is pumped. Of the latter, about 15% is repumped at the booster stations.


Because of differences in elevation among city neighborhoods (a difference of 450 feet, for example, between homes in Roxborough and those in South Philadelphia), the city is divided into ten pressure districts. The fact that Philadelphia takes its water from three different river sources also makes some of these districts necessary.

### Areas Where Delivered

Delaware water is delivered generally to those areas of the city east of Broad Street, while Schuylkill water reaches consumers west of Broad Street. There are some exceptions, however, to this pattern of distribution.

Thus Delaware water flows west of Broad Street to some neighborhoods south of Erie Avenue. It is also delivered to West Oak Lane and Chestnut Hill, and it may mix with Schuylkill water in the vicinity of East Park Reservoir before the latter water enters central city. Schuylkill water may also cross the Broad Street boundary: it serves the area bounded by Lehigh, Wyoming, and Kensington Avenue, and Roosevelt Boulevard.

Because of changes in consumer demands, and the need for occasional changes in plant operations, it is uncertain which of the river waters, or what com-



**Spring Cleaning: A sedimentation basin at the Belmont Plant gets a periodic cleaning. Mud at the bottom was formed from suspended particles which settled out of the river water.**

ination of them, will be received in some areas along the north-south mid-axis of the city represented by Broad Street. West Philadelphia, however, receives only Schuylkill water.

The preceding is of particular interest to those who may be affected by changes in the mineral content of the water, since the Schuylkill water contains in solution about twice the amount present in Delaware water. In the 10-year period 1961-70, the annual hardness of water delivered to distribution from the Torresdale Plant on the Delaware averaged 99 parts per million; annual hardness of water from the plants on the Schuylkill averaged 164 parts per million.

The total population served is 1.95 million. To these customers the Water Department distributed an average of 363 million gallons daily in each of the last two fiscal years, July 1, 1971 - June 30, 1973. This was about 186 gallons per day for every person in Philadelphia.

In addition, the department delivered 4.3 million gallons of water daily to the Bucks County Water and Sewer Authority for distribution in lower Bucks County.

The distribution system contains 3,200 miles of pipes of various sizes, from three inches to seven feet nine inches in diameter. About 142 miles of this pipe are three feet or wider in diameter. There are nearly 77,000 valves and over 25,000 fire hydrants.

Besides the regular distribution system, there is a high pressure fire system covering center city and that part of north central Philadelphia lying east of Broad Street and south of Lehigh Avenue. This is composed of 63 miles of mains, 1,900 valves, and 1,050 hydrants, together with two pumping stations that deliver water at pressures up to 300 lbs. per sq. in. One station is located at Delaware Avenue and Race Street; the other at 7th Street and Lehigh Avenue.

**MODE OF TREATMENT**

Philadelphia's three water treatment plants are comparatively new. The Torresdale Plant was completed in 1959; the Belmont Plant in 1965; and the principal facilities of the Queen Lane Plant in stages —1954, 1960, 1971. The plants are of the rapid-sand filter type, with automatic and semi-automatic controls. It is planned to bring all the plant treatment processes under computer control within the next few years.

Daily output of the water treatment plants, in millions of gallons daily, averaged as follows during the last two fiscal years:

|                  | 1972-73* | 1971-72* |
|------------------|----------|----------|
| Belmont .....    | 64.7     | 61.8     |
| Queen Lane ..... | 100.7    | 104.0    |
| Torresdale ..... | 213.7    | 213.9    |

\* July 1 of one year to June 30 of next

Although there is some variation at the plants, the treatment process comprises pre-chlorination and pre-sedimentation, chemical treatment, flocculation, sedimentation, filtration, and post chemical treatment.


The first step in treatment is chlorination. The chlorine is added to the water to destroy taste-and odor-producing materials which are chiefly organic matter. This may include the wastes of industries as well as those of natural origin.

Initial chlorination takes place in a large raw-water reservoir, where the chlorine takes effect and some suspended matter settles out as the water moves slowly through.

The second step is injection of other chemicals into the raw water as it passes under a chemical or pre-treatment building. At this point, alum or ferric chloride or ferrous chloride may be added to promote the later formation of "floc," and chemicals such as carbon or sodium chlorite may be used to control taste and odor.

The third step is for the chemical-laden water to pass through small basins, where the chemicals and water are mixed for more than a half-hour by giant revolving paddles. The mixing causes the formation of "floc," tiny granules resembling snowflakes. The floc will enmesh suspended impurities in the water.

When necessary, lime is added to the water to neutralize acidity and create optimum conditions for the formation of floc.



**Giant Water Tunnel:** River water began flowing to the Queen Lane Plant through a new tunnel in May, 1973. The concrete-lined tunnel at right is 6,000 feet long and can carry up to 150 million gallons a day. The plant's filter beds are shown above.



Enmeshment of suspended particles by the floc takes place in large sedimentation basins to which the water next flows. In these basins the water remains quiescent for two to four hours, and the floc settles to the bottom, taking with it more than 90% of the suspended impurities. This prepares the water for filtration.

The water is then filtered through beds of sand and gravel, which remove all particles that remain after the settling period.

As the final step in treatment, the chlorine content of the water is adjusted to ensure safety, and ammonia may be added to counteract chlorinous tastes and odors. At various steps in the treatment process, additional chemicals may be used, or the usual chemicals replaced by others. This is governed by the changes in the condition of the raw water supply.

To help prevent tooth decay in children, fluoride is also added to the water.

Because treatment steps differ slightly at the plants, the successive steps are summarized below:

**Belmont:** (1) Pre-chlorination to free chlorine residual, (2) settling for 22 hours, (3) application of chemicals—chlorine or chlorine dioxide, alum with lime for pH adjustment, carbon, and ammonia, (4) rapid mixing of chemicals with water, (5) slow mixing of chemicals with water to form "floc," (6) settling, (7) rapid sand filtration, (8) post treatment, including chlorination, metaphosphate treatment, fluoridation, ammonia, and pH control with lime.

**Queen Lane:** (1) Pre-chlorination to free chlorine residual, (2) settling for 20 hours, (3) application of chemicals—chlorine, alum, with lime for pH adjustment, and carbon, (4) rapid mixing of chemicals with water, (5) slow mixing of chemicals with water


to form "floc," (6) settling, (7) rapid sand filtration, (8) post treatment, including chlorination, fluoridation, caustic soda for pH control, and (for high service and Roxborough express water only) metaphosphate treatment.

**Torresdale:** (1) Pre-chlorination to free chlorine residual, or application of chlorine dioxide, (2) pre-sedimentation, (3) application of chemicals—ferric chloride or ferrous chloride or alum, with lime for pH adjustment, chlorine or chlorine dioxide, and carbon, (4) rapid mixing of chemicals with water, (5) slow mixing of chemicals with water to form "floc," (6) settling, (7) rapid sand filtration, (8) post treatment, including chlorination and fluoridation; also pH adjustment with lime when required.


All water withdrawn from the East Park and Oak Lane Reservoirs is rechlorinated before entering the distribution system. Water at Oak Lane and East Park is treated with chlorine dioxide through the spring, summer and autumn to control algae.

**Quality Control:** The Water Department guards the quality of its water, from the river to the home faucet. Along the rivers, it maintains electronic monitoring stations and also collects river water samples by boat. In the plants, laboratory personnel check the water at every treatment stage, and this is followed by regular sampling of 85 points in the distribution system. Laboratories make 750,000 wet chemical tests on water each year, and the equivalent of hundreds of thousands of other tests by electronic testing devices.

The city's drinking water, in its finished form, meets or surpasses all of the quality standards of the U.S. Public Health Service, and meets most of the very strict quality goals of the American Water Works Association. It is rated as one of the purest treated waters in America.



**Water Distribution:** Two million Philadelphians receive water through a network of 3,200 miles of mains. These mains range from three inches to nearly eight feet in diameter. At left, a huge valve has just been inserted into a main. The valve will make it possible to control flow through the main.



Belmont Water Treatment Plant

## WATER SYSTEM CAPACITIES — 1973

### PLANT TREATMENT CAPACITIES

(in millions of gallons daily)

|                         | RATED      | PEAK RATE  |
|-------------------------|------------|------------|
| <b>BELMONT PLANT</b>    | <b>78</b>  | <b>108</b> |
| <b>QUEEN LANE PLANT</b> | <b>120</b> | <b>150</b> |
| <b>TORRESDALE PLANT</b> | <b>282</b> | <b>423</b> |

### PLANT RETENTION CAPACITIES

(in millions of gallons)

|                          |                                    | TOTAL |
|--------------------------|------------------------------------|-------|
| <b>BELMONT PLANT:</b>    | Two 36-MG pre-sedimentation basins | 72    |
|                          | Four sedimentation basins          | 14.2  |
|                          | Three filtered water basins        | 38.2  |
|                          | Filtered water clear well          | 1.8   |
| <b>QUEEN LANE PLANT:</b> | Pre-sedimentation basin            | 177   |
|                          | Four 3-MG upper settling basins    | 12    |
|                          | Four 3-MG lower settling basins    | 12    |
|                          | Four filtered water basins         | 90    |
| <b>TORRESDALE PLANT:</b> | Pre-sedimentation basin            | 176   |
|                          | Four 10-MG sedimentation basins    | 40    |
|                          | Five filtered water basins         | 193   |

### OTHER RETENTION CAPACITIES

(in millions of gallons)

|                          |                             | TOTAL |
|--------------------------|-----------------------------|-------|
| <b>UPPER ROXBOROUGH:</b> | Filtered water basins       | 25.6  |
|                          |                             |       |
| <b>LOWER ROXBOROUGH:</b> | Filtered water basins       | 3     |
| <b>OPEN RESERVOIRS:</b>  | East Park (filtered water)  | 677   |
|                          | Oak Lane (filtered water)   | 70    |
| <b>STANDPIPES:</b>       | Two 5-MG Somerton tanks     | 10    |
|                          | Two 5.5-MG Roxborough tanks | 11    |
|                          | Fox Chase tank              | 1.5   |

### PUMPING STATION CAPACITIES

(in millions of gallons daily)

|  | TOTAL |
|--|-------|
| <b>RAW WATER:</b>  |       |
| Belmont Station (Schuylkill)                                       | 140   |
| Queen Lane Station (Schuylkill)                                    | 200   |
| Torresdale Station (Delaware)                                      | 360   |
| <b>FILTERED WATER:</b>   |       |
| 1. Treated Schuylkill Water  |       |
| Belmont High Service Station                                       | 42    |
| Chestnut Hill Booster Station                                      | 8.5   |
| East Park Booster Station  | 75    |
| Queen Lane High Service Station                                    | 77.5  |
| Roxborough High Service Station                                    | 45    |
| 2. Treated Delaware Water  |       |
| Fox Chase Booster Station  | 25.3  |
| Lardner's Point Station  | 240   |
| Oak Lane High Service Station                                      | 50    |
| Torresdale High and Low Service Station (200 MGD low, 63 MGD high) | 263   |
| West Oak Lane Booster Station                                      | 27.5  |
| <b>HIGH PRESSURE:</b>  |       |
| Fairhill Station   | 21.6  |
| Race Street Station  | 21.6  |
| (Each high pressure station can pump 15,000 gallons per minute)    |       |


*NOTE: At each stage, the combined capacities of the water system facilities (whether treatment plants, reservoirs, or pumping stations) are much greater than average daily demand by consumers. This enables the Water Department to meet emergencies, to supply peak needs at certain hours or seasons, and to continue operation when some facilities have to be taken out of service.*

# CHEMICALS USED BY THE PHILADELPHIA WATER SYSTEM

| CHEMICAL  | STORAGE   | FEED   | POINTS OF APPLICATION                          | PURPOSE  | MAXIMUM DOSAGES |
|---|---|--|--|--|-----------------|
| <b>Alum:</b> Commercial aluminum sulphate<br>$Al_2(SO_4)_3 \cdot 18 H_2O$ | Dry in bulk, liquid in plastic or lead-lined tanks        | Belt-type dry feed, rotodip, or pump and control valve               | Inlet to rapid mix or mixing basin             | Clarification  | 2.5 gpg         |
| <b>Lime:</b> Oxide and hydrate<br>$CaO$ and $Ca(OH)_2$                    | Dry and bulk  | Belt-type dry feed (slakers for the oxide) or pump and control valve | Inlet to rapid mixing basin or filter effluent | pH adjustment, also to increase alkalinity                     | 2 gpg           |
| <b>Chlorine:</b> $Cl_2$   | 150 - lb. cylinders, ton-cylinders, 55-ton R.R. tank cars | Commercial chlorinators with evaporators                             | Plant intake, rapid mix, or filter effluent    | Taste and odor control (contact 16 to 20 hours), sterilization | 16 ppm          |
| <b>Activated Carbon:</b> C  | Bags; also bulk truck or R.R. car to slurry               | With slurry feeder pump or rotodip                                   | Rapid mix or applied to filters                | Taste and odor control   | 12 ppm          |
| <b>Hexametaphosphate:</b><br>$(PO_3)_6$                                   | Bags, 1 1/2-ton unit hoppers                              | Solution tank and diaphragm feeder pump                              | Filter effluent                                | Reduce corrosion in distribution                               | 1 ppm           |
| <b>Sodium Chlorite:</b><br>$NaClO_2$                                      | Liquid in stainless steel or rubber lined steel tanks     | Solution tank and auxiliary tank to feeder pump                      | Plant intake, rapid mix, or filter effluent    | Form chlorine dioxide for control of tastes, odors, or algae   | 1.5 ppm         |

|  |                          |  |  |                           |        |
|--|--------------------------|--|--|---------------------------|--------|
| <b>Fluosillic Acid:</b><br>$H_2SiF_6$                    | Rubber-lined steel tanks | Measuring tank and diaphragm feeder pump | Filter effluent  | Reduction of dental decay | 1 ppm  |
| <b>Ferric Chloride:</b><br>$FeCl_3$                      | Fiberglass-lined tanks   | Rotodip liquid feed                      | Inlet to rapid mixing basin                            | Clarification             | 1 gpg  |
| <b>Ferrous Chloride:</b><br>$FeCl_2$                     | Fiberglass-lined tanks   | Rotodip liquid feed                      | Inlet to rapid mixing basin                            | Clarification             | 1 gpg  |
| <b>Ammonium Hydroxide:</b><br>$NH_4 OH$                  | Steel tanks              | Diaphragm feeder pump                    | Inlet to rapid mix or mixing basin and filter effluent | Taste and odor control    | 1 ppm  |
| <b>Caustic Soda:</b> Commercial Sodium Hydroxide<br>NaOH | Steel tanks              | Feeder pump                              | Filter effluent  | pH adjustment             | 12 ppm |
| <b>Sulfur Dioxide:</b> $SO_2$                            | Ton cylinders            | Commercial sulfunators                   | Rapid mix, filter effluent, basin effluent             | Reduce chlorine residual  | 2 ppm  |

NOTE: gpg—grains per gallon; ppm—parts per million. One grain per gallon adds up to approximately 143 lbs. of chemical per million gallons of water while one part per million would result in 8.34 lbs. per million gallons.



**Fig. 1**  
**Philadelphia Water Facilities**  
**and Water Pressure Districts**

- Treatment Plant
- River Water Pumps
- High and Low Service Pumps

- Treatment Plant
  - High Service and Roxborough Express Pumps
  - River Water Pumps
- QUEEN LANE**
- Treatment Plant
  - High Service Pumps
  - River Water Pumps
- BELMONT**


- KEY**
- Treatment Plants
  - ★ River Water Pumping Stations
  - ⊙ Filtered Water Pumping Stations
  - ☆ High Pressure Pumping Stations (for fire protection only)
  - ◐ Tanks for Filtered Water
  - Open Reservoirs for Filtered Water
- Note: There are also underground basins for filtered water at each treatment plant and in Upper Roxborough.

**Water Pressure Districts**


1. Torresdale water pumped by Torresdale High Service and Fox Chase Booster Stations.
2. Torresdale water pumped by Torresdale Low Service Station. Pump capacity—85 PSI.
3. Torresdale water pumped by Torresdale Low Service Station. Pump capacity—60 PSI.
4. Torresdale water pumped by Lardner's Point High Service Station. Queen Lane water distributed by gravity from Queen Lane Plant and East Park Reservoir.
5. Belmont water distributed by gravity from Belmont Plant.
6. Belmont water pumped by Belmont High Service Station.
7. Queen Lane water supplied by gravity from Lower Roxborough Filtered Water Basin.
8. Queen Lane water pumped by Queen Lane High Service Station; also distributed by gravity from Upper Roxborough Filtered Water Basin. Torresdale water pumped by Oak Lane Booster Station.
9. Queen Lane water pumped by Roxborough High Service Station. Torresdale water pumped by West Oak Lane Station.
10. Either Torresdale or Queen Lane water pumped by Chestnut Hill Booster Station from April through November. At other times, the district is supplied directly by the Roxborough and West Oak Lane Stations.

*Note on Water Pressures: The normal range of water pressures, as received by consumers, is shown on the map for each district. Thus 50 PSI-75 PSI (for District 1) denotes a pressure range of 50 to 75 pounds per square inch.*

**Fig- 1-A**  
**CHIEF WATER**  
**SUPPLY LINES**




# FIG. II-TORRESDALE WATER TREATMENT PLANT



**Chemicals Applied**


- A—Chlorine or chlorine dioxide
- B—Ferric or ferrous chloride, alum, lime, carbon, chlorine or chlorine dioxide
- C—Lime, fluoride, chlorine or chlorine dioxide

# FIG. II-A-DISTRIBUTION FROM TORRESDALE



# FIG. III-QUEEN LANE WATER TREATMENT PLANT

**Schuylkill River**



**DISTRIBUTION**  
Supply Pressure District 4 with 60 to 65 M.G.D. annually.




**DISTRIBUTION**  
Supplies Pressure District 8 with average of 10 M.G.D. annually. Pressure District 8 is also supplied by Oak Lane Booster Pumps and Upper Roxborough gravity.

**DISTRIBUTION**  
Supplies Upper Roxborough Filtered Water Basins with average of 22 to 23 M.G.D. annually.


**Chemicals Applied**

- A—Chlorine
- B—Alum, chlorine, lime, carbon
- C—Chlorine or sulfur dioxide
- D—Chlorine, fluoride, caustic soda
- E—Metaphosphate




**Pressure Districts**

# FIG. IV-DISTRIBUTION FROM ROXBOROUGH



**FIG. V-BELMONT WATER TREATMENT PLANT**



at your service

